5.3.25 **B25_TW100_E** - electrical services on timber wall ≥ 100 mm - TECNOBOARD

Description

- Timber wall - thickness ≥ 100 mm.
- Sealing with TECNOBOARD panel installed flush with the outside of the wall on both sides.
- Maximum sealing opening 1200x600 mm.
- The TECNOBOARD panel must be fixed to the outside of the support overlapping it by 100 mm with 300 mm pitch screws.



Classification and field of application

Type of electrical service	Diameter [mm]	Max. aperture [mm]	Classification
Single cable, cable bundle or in conduit	≤ 50	1200x600	EI 90
Bundled electrical cables	≤ 100	1200x600	EI 60