MARVON

5.3.14 **B27_TF150_IP** - incombustible pipes on timber floor ≥ 150 mm - TECNOBOARD

Description

- Timber floor - tickness ≥ 150 mm.
- Sealing with double TECNOBOARD panel, one installed flush inside the attic and one outside the opening.
- Pipe insulation LI.
- Maximum sealing opening 1200x600 mm.



Classification and field of application

Type of pipe	Diameter [mm]	Insulation	Max. aperture [mm]	Classification
Incombustible	≤ 273	80 kg/m^3 stone wool 30 mm thick	1200x600	EI 60 C/U
Copper	≤ 54	80 kg/m^3 stone wool 30 mm thick	1200x600	EI 90 C/C