5.3.19 **B28_TF150_MP** - multilayer pipes on timber floor ≥ 150 mm - TECNOBOARD

Description

- Timber floor - tickness ≥ 150 mm.
- Sealing with double TECNOBOARD panel, one installed flush inside the attic and one outside the opening.
- Pipe insulation CS.
- Maximum sealing opening 1200x600 mm.



Classification and field of application

Type of pipe	Diameter [mm]	Insulation	Max. aperture [mm]	Classification
Multilayer pipe	≤ 75	80 kg/m^3 stone wool 30 mm thick	1200x600	EI 60 C/C