5.3.3 **B29_TW100_CP** - combustible pipes on timber wall ≥ 100 mm - TECNOBOARD

Description

- Timber wall - thickness ≥ 100 mm.
- Sealing both sides with double TECNOBOARD.

Contact Marvon for more information.



Classification and field of application

Type of pipe	Diameter [mm]	Max. aperture [mm]	Classification
PVC	≤ 6	1200x600	EI 120 (U/C)
	≤ 32	1200x600	EI 90 (U/C)
PE	≤ 32	1200x600	EI 90 (U/C)
PP	≤ 32	1200x600	EI 60 (U/C)