MARVON

5.10.18 **S34_TF150_IP** - incombustible pipes on timber floor ≥ 150 mm - TECNO-S 240

Description

- Timber floor - thickness ≥ 150 mm.
- Sealing on both sides.
- Pipe insulation LI/CI.
- Maximum opening Ø 293 mm for incombustible pipes.
- Maximum opening Ø 220 mm for copper pipes.



Classification and field of application

Type of pipe	Diameter [mm]	Insulation	Sealant depth [mm]	Backing	Classification
Incombustible	≤ 273	80 kg/m³ stone wool 30 mm thick	25	40 kg/m³ stone wool 25 mm thick	EI 60 (C/C)
Copper	≤ 15	80 kg/m³ stone wool 30 mm thick	25	40 kg/m³ stone wool 25 mm thick	EI 120 (C/C)
	16 - 54				EI 90 (C/C)