5.1.23 **T19_TF150_E** - electrical services on timber floor ≥ 150 mm - TECNOCOLLAR

Description

- Timber floor - thickness ≥ 150 mm.
- Fixing with wood screws.
- TECNOCOLLAR is installed on the underside of the floor, fire side.
- Collar Ø 160 mm required.
- If cold smoke sealing is required, insert a spacer of stone wool between the cables and the support.



Classification and field of application

Type of electrical service	Diameter [mm]	Classification
Single or bundled electrical cables	Cable ≤ 21 Bundle ≤ 160	EI 120