MARVON

5.1.25 **T20_TW100_H** - empty holes on timber wall ≥ 100 mm - TECNOCOLLAR

Description

- Timber wall - tickness ≥ 100 mm.
- Fixing:
  A. On wooden wall: with wood/plasterboard screws ≥ Ø 4 mm.
- TECNOCOLLAR is installed on both sides.
- Insert on both sides, inside the hole, 25 mm of stone wool with minimum density of 33 kg/m^3.



Classification and field of application

Type	Diameter [mm]	Classification
Empty hole	≤ 160	EI 90