MARVON

5.1.27 **T21_TF150_H** - empty holes on timber floor ≥ 150 mm - TECNOCOLLAR

Description

- Timber floor - tickness ≥ 150 mm.
- Fixing with wood screws.
- TECNOCOLLAR is installed on the underside of the floor, fire side.
- Insert on fire side, inside the hole, 25 mm of stone wool with minimum density of 33 kg/m^3.



Classification and field of application

Type	Diameter [mm]	Classification
Empty hole	≤ 160	EI 120